



Environmental and Laboratory Services
 90 ½ West Blackwell St., Dover, New Jersey 07801
 (973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: September 12, 2017
 Client: Midland Park BOE
 Address: 250 Prospect Street
 Midland Park, NJ 07432

Project: Godwin School

Sample description: Drinking Water / 1st Draw / DWS3804-1
 Sample location: Field Blank
 Sampled by: Client
 Sample date: 08/29/17
 Time: 07:19
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	09/06/17	18:51	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS3804-2
 Sample location: Room #10 Bubbler
 Sampled by: Client
 Sample date: 08/29/17
 Time: 07:20
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	14.3 µg/L	15 µg/L	09/06/17	18:58	1	2.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen (For SV)
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

September 12, 2017
 Date