



Environmental and Laboratory Services

90 ½ West Blackwell St., Dover, New Jersey 07801

(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: June 15, 2017
Client: Midland Park BOE
Address: 250 Prospect Street
Midland Park, NJ 07432

Project: Godwin School

Sample description: Drinking Water / 1st Draw / DWS5604-1
Sample location: FIELD BLANK
Sampled by: D. Mitchell / S. Flyte
Sample date: 06/03/17
Time: 07:16
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/09/17	17:23	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-2
Sample location: MPGS-DW-1
Sampled by: D. Mitchell / S. Flyte
Sample date: 06/03/17
Time: 07:17
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.54 µg/L	15 µg/L	06/09/17	17:29	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-3
Sample location: MPGS-TL-2
Sampled by: D. Mitchell / S. Flyte
Sample date: 06/03/17
Time: 07:18
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.81 µg/L	15 µg/L	06/09/17	17:36	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-4
Sample location: MPGS-DW-LEFT-3
Sampled by: D. Mitchell / S. Flyte
Sample date: 06/03/17
Time: 07:19
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	8.50 µg/L	15 µg/L	06/09/17	17:42	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-5
 Sample location: MPGS-DW-RIGHT-4
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:20
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.81 µg/L	15 µg/L	06/09/17	17:49	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-6
 Sample location: MPGS-DW-5
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:21
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.74 µg/L	15 µg/L	06/09/17	17:55	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-7
 Sample location: MPGS-DW-6
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:22
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.34 µg/L	15 µg/L	06/09/17	18:01	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-8
 Sample location: MPGS-DW-7
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:22
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	9.20 µg/L	15 µg/L	06/09/17	18:08	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-9
 Sample location: MPGS-DW-8
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:23
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	14.3 µg/L	15 µg/L	06/09/17	18:33	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-10
 Sample location: MPGS-DWB-9
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:24
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.32 µg/L	15 µg/L	06/09/17	19:06	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-11
 Sample location: MPGS-DW-10
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:25
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.24 µg/L	15 µg/L	06/09/17	19:12	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-12
 Sample location: MPGS-WF-RIGHT-12
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:26
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	6.72 µg/L	15 µg/L	06/09/17	19:18	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-13
 Sample location: MPGS-DWB-13
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:27
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.56 µg/L	15 µg/L	06/09/17	19:24	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-14
 Sample location: MPGS-DW-14
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:28
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.56 µg/L	15 µg/L	06/09/17	19:31	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-15
 Sample location: MPGS-DW-15
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:30
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.19 µg/L	15 µg/L	06/09/17	19:37	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-16
 Sample location: MPGS-WF-RIGHT-17
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:32
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	10.2 µg/L	15 µg/L	06/09/17	19:50	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-17
 Sample location: MPGS-DW-18
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:33
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.74 µg/L	15 µg/L	06/09/17	19:50	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-18
 Sample location: MPGS-DW-19
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:34
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	7.00 µg/L	15 µg/L	06/09/17	20:03	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-19
 Sample location: MPGS-DW-20
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:36
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.51 µg/L	15 µg/L	06/09/17	20:09	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-20
 Sample location: MPGS-DWB-21
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:37
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	7.84 µg/L	15 µg/L	06/09/17	20:16	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-21
 Sample location: MPGS-DW-22
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:37
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	10.1 µg/L	15 µg/L	06/09/17	20:22	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-22
 Sample location: MPGS-DW-23
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:40
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	7.33 µg/L	15 µg/L	06/09/17	20:28	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-23
 Sample location: MPGS-DW-24
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:41
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.85 µg/L	15 µg/L	06/09/17	20:35	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-24
 Sample location: MPGS-DWB-25
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:42
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/09/17	20:41	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-25
 Sample location: MPGS-DW-26
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:42
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.02 µg/L	15 µg/L	06/09/17	20:48	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-26
 Sample location: MPGS-DW-27
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:43
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	16.5 µg/L	15 µg/L	06/09/17	20:54	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-27
 Sample location: MPGS-DW-28
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:44
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/09/17	21:00	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-28
 Sample location: MPGS-FP-LEFT-29
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:44
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.22 µg/L	15 µg/L	06/09/17	21:24	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-29
 Sample location: MPGS-FP-RIGHT-30
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:45
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	14.7 µg/L	15 µg/L	06/09/17	21:48	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-30
 Sample location: MPGS-DWB-31
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:48
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/09/17	21:54	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-31
 Sample location: MPGS-DW-32
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:49
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/09/17	22:00	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-32
 Sample location: MPGS-DWB-33
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:51
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/09/17	22:05	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-33
 Sample location: MPGS-DW-34
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:51
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/09/17	22:11	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-34
 Sample location: MPGS-DW-35
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:52
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/09/17	22:18	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-35
 Sample location: MPGS-DW-36
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:54
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/09/17	22:24	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-36
 Sample location: MPGS-DWB-37
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:55
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.54 µg/L	15 µg/L	06/09/17	22:30	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5604-37
 Sample location: MPGS-DW-38
 Sampled by: D. Mitchell / S. Flyte
 Sample date: 06/03/17
 Time: 07:55
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/09/17	22:42	1	2.00 µg/L

µg/L = micrograms per liter

Field Notes:
 DWS5604-11 (MPGS-DW-10) – Low pressure
 DWS5604-16 (MPGS-WF-RIGHT-17 – Extremely low pressure

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan Van Veen (For SV)
 Susan Van Veen, Lab Manager
 NJ Laboratory Certification ID # 14013

June 15, 2017
 Date

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Asc./HCl Vials pH: _____
 # HCl Vials pH: _____
 # Na₂S₂O₃ Cl₂: _____
 # HNO₃ (1.5N) pH: 5.2
 # H₂SO₄ pH: _____
 # NaOH pH: _____
 # unpreserved _____
 # other _____
 # other _____

Customer Name: Midland Park Godwin School
Address: 41 East Center Street
 Midland Park NJ 07432
County/Municipality: _____
Phone: _____
Work: _____

report to: _____
 Scott Collins
 Scollins@MPSNJ.org

Agra Environmental Services
 90½ West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake
Project: _____ for laboratory use only.

Field ID	Lab ID:	Collection		Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	
		Date	Time							
FIELD BLANK	DW55604	6/3/17	0716	X		DW	1	NH03	1st Draw PB < 2 µg/L	6/9/17 1723
MPGS-DW-1		6/3/17	0717	X		DW	1	NH03	1st Draw PB 3.54 µg/L	1729
MPGS-TL-2		6/3/17	0718	X		DW	1	NH03	1st Draw PB 3.81 µg/L	1736
MPGS-DW-LEFT-3		6/3/17	0719	X		DW	1	NH03	1st Draw PB 8.50 µg/L	1742
MPGS-DW-RIGHT-4		6/3/17	0710	X		DW	1	NH03	1st Draw PB 3.81 µg/L	1749
MPGS-DW-5		6/3/17	0721	X		DW	1	NH03	1st Draw PB 4.74 µg/L	1755
MPGS-DW-6		6/3/17	0724	X		DW	1	NH03	1st Draw PB 3.34 µg/L	1801
MPGS-DW-7		6/3/17	0723	X		DW	1	NH03	1st Draw PB 9.20 µg/L	1808
MPGS-DW-8		6/3/17	0723	X		DW	1	NH03	1st Draw PB 14.3 µg/L	1833
MPGS-DWB-9		6/3/17	0724	X		DW	1	NH03	1st Draw PB 3.32 µg/L	1906

Sampled By (name/company): DM/SF

State Forms Needed (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):

Standard

NJ Reduced

Other (Specify)

Cooler Temperature Upon Receipt at lab: _____

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date:	Time:	Received By:	Date:	Time:
<i>Mary Pate</i>	6/3/17	1145			

Scanned _____

Date Faxed _____
 Invoice Number _____
 Is sample known to be hazardous? (circle one)
 Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Midland Park Godwin School Address: 41 East Center Street Midland Park NJ 07432 County/Municipality: Phone: Work:	report to: Scott Collins Scollins@MPSNJ.org Phone: (973) 989-0010 Fax: (973) 989-0156
------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------



Agra Environmental Services
 90 1/2 West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake		PWSID# NJ		ANALYSIS REQUESTED		Field Analysis	
Project:	Lab ID:	Collection	Grab	Comp	Matrix	# of Bottles	Preservative
	DW555004	Date: 6/3/17 Time: 0715	X	DW	DW	1	NHO3
		Date: 6/3/17 Time: 0715	X	DW	DW	1	NHO3
		Date: 6/3/17 Time: 0716	X	DW	DW	1	NHO3
		Date: 6/3/17 Time: 0727	X	DW	DW	1	NHO3
		Date: 6/3/17 Time: 0728	X	DW	DW	1	NHO3
		Date: 6/3/17 Time: 0730	X	DW	DW	1	NHO3
		Date: 6/3/17 Time: 0732	X	DW	DW	1	NHO3
		Date: 6/3/17 Time: 0733	X	DW	DW	1	NHO3
		Date: 6/3/17 Time: 0734	X	DW	DW	1	NHO3
State Forms Needed (circle one): Yes or No NJDEP Laboratory Certification (Dover, NJ) #14013 NJDEP Laboratory Certification (Marlboro, NJ) #13033							
Reporting Requirements (Check Box): <input type="checkbox"/> NJ Reduced <input type="checkbox"/> Other (Specify)							

1912 gm
1918 gm
1924
1931
1937
6/9/17 ASD
ASD
2003

Sampled By (name/company): DWL SF

indicate laboratory location where analysis requested was performed

Cooler Temperature Upon Receipt at lab: _____

Sample Custody Exchanges (Please use full legal signature)			
Relinquished By:	Received By:	Date:	Time:
<i>[Signature]</i>	<i>[Signature]</i>	6/3/17	1045
		Date:	Time:
		Date:	Time:
		Date:	Time:
		Date:	Time:

Scanned _____

Date Faxed _____
 Invoice Number _____

Is sample known to be hazardous? (circle one)
 Yes or No

#NAME?

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST



Agra Environmental Services
 90½ West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Customer Name: Midland Park Godwin School
 Address: 41 East Center Street
 Midland Park NJ 07432
 County/Municipality:
 Phone:
 Work:

Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake
 Project: _____ for laboratory use only Page 1 of 1

Field ID	Lab ID:	Collection		PWSID# NJ			ANALYSIS REQUESTED	Field Analysis
		Date	Time	Grab	Comp	Matrix		
MPGS-FP-RIGHT-30	DW55604	6/3/17	0745	X	DW	1	NHO3	1st Draw PB 14.7 ug/L 6/9/17 2148 BM
MPGS-DWB-31	30	6/3/17	0748	X	DW	1	NHO3	1st Draw PB <2 ug/L 2154
MPGS-DW-32	31	6/3/17	0749	X	DW	1	NHO3	1st Draw PB <2 ug/L 2200
MPGS-DWB-33	32	6/3/17	0751	X	DW	1	NHO3	1st Draw PB <2 ug/L 2205
MPGS-DW-34	33	6/3/17	0751	X	DW	1	NHO3	1st Draw PB <2 ug/L 2241
MPGS-DW-35	34	6/3/17	0752	X	DW	1	NHO3	1st Draw PB <2 ug/L 2248
MPGS-DW-36	35	6/3/17	0754	X	DW	1	NHO3	1st Draw PB <2 ug/L 2224
MPGS-DWB-37	36	6/3/17	0755	X	DW	1	NHO3	1st Draw PB 5.54 ug/L 2230
MPGS-DW-38	37	6/3/17	0755	X	DW	1	NHO3	1st Draw PB <2 ug/L 2242

State Forms Needed (circle one): Yes or No
 indicate laboratory location where analysis requested was performed
 NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)
<input type="checkbox"/>		<input type="checkbox"/>	

Cooler Temperature Upon Receipt at lab: _____

Sample Custody Exchanges (Please use full legal signature)		Scanned	
Relinquished By:	Received By:	Date:	Time:
<i>Drew Duke</i>		6/3/17	1045

Date Faxed: _____ Invoice Number: _____
 Is sample known to be hazardous? (circle one)
 Yes or No

Attachment C – Drinking Water Outlet Inventory
 (Complete for each school)

Name of School: Godwin School Address: 41 East Center Street, Midland Park, NJ 07432

Grade Levels: _____ Year School Constructed: _____ Renovated/Additions: _____

Individual school project officer Name/Signature: _____ Date Completed: _____

#5	Type	Location	Code	Operational ⁶ (Y/N)	Signs of Corrosion ⁷ (Y/N)	Filter ⁸ (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	FIELD BLANK												
02	POE	1 st FL ROOM 1	MPGS-DW-1										
03	TL	1 st FL ROOM 2A	MPGS-TL-2										
04	DW – WF- WHITE	1 st FL BY 2a & 2b	MPGS-DW-left- 3										
05	DW – WF- WHITE	1 st FL BY 2a & 2b	MPGS-DW- Right-4										
06	DW	1 st FL ROOM 3	MPGS-DW-5										
07	DW	1 st FL ROOM 3	MPGS-DW-6										
08	DW	1 st FL ROOM 4	MPGS-DW-7										

⁵ Number outlets starting at the closest outlet to the Point of Entry (POE).
⁶ Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.
⁷ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.
⁸ Document on Attachment D- Filter Inventory.

