



**Environmental and Laboratory Services**  
 90 ½ West Blackwell St., Dover, New Jersey 07801  
 (973) 989-0010 P, (973) 989-0156 F

**Analytical Results**

Date: June 15, 2017  
 Client: Midland Park BOE  
 Address: 250 Prospect Street  
 Midland Park, NJ 07432

**Project: Midland Park High School**

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-1  
 Sample location: FIELD BLANK  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:04  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/09/17	22:48	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-2  
 Sample location: MPHS-POE-01 (Men's Room)  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:05  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.40 µg/L	15 µg/L	06/09/17	22:54	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-3  
 Sample location: MPHS-WC-02  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:07  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.98 µg/L	15 µg/L	06/09/17	23:00	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-4  
 Sample location: MPHS-FP-03  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:09  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	7.34 µg/L	15 µg/L	06/09/17	23:06	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-5  
 Sample location: MPHS-FP-04  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:09  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.50 µg/L	15 µg/L	06/09/17	23:11	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-6  
 Sample location: MPHS-FP-05  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:10  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	8.46 µg/L	15 µg/L	06/09/17	23:17	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-7  
 Sample location: MPHS-FP-06  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:10  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.75 µg/L	15 µg/L	06/09/17	23:23	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-8  
 Sample location: MPHS-1F-NS-7  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:11  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.00 µg/L	15 µg/L	06/09/17	23:29	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-9  
 Sample location: MPHS-TL-8  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:13  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.90 µg/L	15 µg/L	06/15/17	24:42	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-10  
 Sample location: MPHS-WC-9  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:14  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/09/17	23:35	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-11  
 Sample location: MPHS-WC-10  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:14  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/09/17	23:59	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-12  
 Sample location: MPHS-WC-11  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:18  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/10/17	00:23	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-13  
 Sample location: MPHS-WC-12  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:19  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/10/17	00:29	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-14  
 Sample location: MPHS-WC-13  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:30  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/10/17	00:36	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-15  
 Sample location: MPHS-IM-14  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:35  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.14 µg/L	15 µg/L	06/10/17	00:42	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-16  
 Sample location: MPHS-WC-15  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:36  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/10/17	00:48	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-17  
 Sample location: MPHS-WC-16  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:36  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/10/17	00:54	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-18  
 Sample location: MPHS-WC-17  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:38  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.97 µg/L	15 µg/L	06/10/17	00:59	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-19  
 Sample location: MPHS-WC-18  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:38  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	11.2 µg/L	15 µg/L	06/10/17	01:05	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-20  
 Sample location: MPHS-TL-19  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:39  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/10/17	01:18	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-21  
 Sample location: MPHS-WC-20  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:41  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/10/17	01:24	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-22  
 Sample location: MPHS-WC-21  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:41  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/10/17	01:29	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-23  
 Sample location: MPHS-WC-22  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:43  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/10/17	01:35	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-24  
 Sample location: MPHS-WC-02A  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:07  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/10/17	01:41	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5606-25  
 Sample location: MPHS-WC-13A  
 Sampled by: D. Mitchell / S. Flyte  
 Sample date: 06/03/17  
 Time: 06:30  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/10/17	01:47	1	2.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susanne VanVeen (for SV)  
 Susanne VanVeen, Lab Manager  
 NJ Laboratory Certification ID # 14013

June 15, 2017  
 Date

# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

# Asc./HCl Vials pH: \_\_\_\_\_  
 # HCl Vials pH: \_\_\_\_\_  
 # Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub> Cl: \_\_\_\_\_  
 # 25 HNO<sub>3</sub> (150 ml) pH: 5.9  
 # H<sub>2</sub>SO<sub>4</sub> pH: \_\_\_\_\_  
 # NaOH pH: \_\_\_\_\_  
 # unpreserved  
 # other  
 # other

**Customer Name:** Midland Park High School  
**Address:** 250 Prospect Street  
 Midland Park NJ 07432  
**County/Municipality:** \_\_\_\_\_  
**Phone:** \_\_\_\_\_  
**Work:** \_\_\_\_\_

**report to:** \_\_\_\_\_  
**Matrix:** Scott Collins  
 Scollins@MPSNJ.org

**Agra Environmental Services**  
 90% West Blackwell Street  
 Dover, NJ 07801  
 Phone: (973) 989-0010  
 Fax: (973) 989-0156

**Matrix Abbreviations:** D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake  
**Project:** PWSID# NJ \_\_\_\_\_ for laboratory use only

Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED
FIELD BLANK	D0555606	6/3/17	0604	X	DW	DW	1	NHO3	1st Draw PB <2.40 ug/L
MPHS-POE-01	Medis Diner - 01A	6/3/17	0605	X	DW	DW	1	NHO3	1st Draw PB 2.40 ug/L
MPHS-POE-02	WC-02	6/3/17	0607	X	DW	DW	1	NHO3	1st Draw PB 2.96 ug/L
MPHS-FP-03	H	6/3/17	0609	X	DW	DW	1	NHO3	1st Draw PB 7.34 ug/L
MPHS-FP-04	S	6/3/17	0609	X	DW	DW	1	NHO3	1st Draw PB 2.50 ug/L
MPHS-FP-05	B	6/3/17	0610	X	DW	DW	1	NHO3	1st Draw PB 8.46 ug/L
MPHS-FP-06	A	6/3/17	0610	X	DW	DW	1	NHO3	1st Draw PB 3.75 ug/L
MPHS-1F-NS-7	B	6/3/17	0611	X	DW	DW	1	NHO3	1st Draw PB 5.00 ug/L
MPHS-TL-8	B	6/3/17	0613	X	DW	DW	1	NHO3	1st Draw PB 3.90 ug/L
MPHS-WC-9	B	6/3/17	0614	X	DW	DW	1	NHO3	1st Draw PB <2.40 ug/L

**Sampled By (name/company):** DML/SE  
 State Forms Needed (circle one): Yes or No  
 NJDEP Laboratory Certification (Dover, NJ) #14013  
 NJDEP Laboratory Certification (Marlboro, NJ) #13033  
 Cooler Temperature Upon Receipt at lab: \_\_\_\_\_

Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)

  

Sample Custody Exchanges (Please use full legal signature)			
Relinquished By:	Date:	Time:	Received By:
<u>Mary Gates</u>	6/3/17	10:30	

  

Scanned	Date:	Time:	Date:	Time:

  

Date:	Time:	Date:	Time:

  

Date:	Time:	Date:	Time:

  

Date Faxed: \_\_\_\_\_  
 Invoice Number: \_\_\_\_\_  
 Is sample known to be hazardous? (circle one)  
 Yes or No

# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Midland Park High School Address: 250 Prospect Street Midland Park NJ 07432 County/Municipality: Phone: Work:	report to: Agra Environmental Services 90½ West Blackwell Street Dover, NJ 07801 Phone: (973) 989-0010 Fax: (973) 989-0156
---	---



Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake		PWSID# NJ		for laboratory use only		Page 1 of 1			
Project:	Lab ID:	Collection	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	Field Analysis
	HWS 51006								
MPHS-WC-10	11	6/3/17 0614	X	DW	DW	1	NHO3	1st Draw PB <2 µg/L	6/8/17 2359 DM
MPHS-WC-11	11	6/3/17 0618	X	DW	DW	1	NHO3	1st Draw PB <2 µg/L	6/10/17 2423
MPHS-WC-12	12	6/3/17 0619	X	DW	DW	1	NHO3	1st Draw PB <2 µg/L	2429
MPHS-DW-13	WC-13	6/3/17 0620	X	DW	DW	1	NHO3	1st Draw PB <2 µg/L	2436
MPHS-IM-14	14	6/3/17 0625	X	DW	DW	1	NHO3	1st Draw PB 3.14 µg/L	2442
MPHS-WC-15	15	6/3/17 0626	X	DW	DW	1	NHO3	1st Draw PB <2 µg/L	2448
MPHS-WC-16	16	6/3/17 0626	X	DW	DW	1	NHO3	1st Draw PB <2 µg/L	2454
MPHS-WC-17	17	6/3/17 0628	X	DW	DW	1	NHO3	1st Draw PB 2.97 µg/L	2459
MPHS-TL-18	WC-18	6/3/17 0628	X	DW	DW	1	NHO3	1st Draw PB 11-2 µg/L	0105
MPHS-TL-19	19	6/3/17 0629	X	DW	DW	1	NHO3	1st Draw PB <2 µg/L	0118

State Forms Needed (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

indicate laboratory location where analysis requested was performed

Reporting Requirements (Check Box):

NJ Reduced  Other (Specify) \_\_\_\_\_

Cooler Temperature Upon Receipt at lab: \_\_\_\_\_

Sample Custody Exchanges (Please use full legal signature)				Scanned
Relinquished By:	Date: 6/21/17	Received By:	Date: _____	Time: _____
Relinquished By:	Date: _____	Received By:	Date: _____	Time: _____
Relinquished By:	Date: _____	Received By:	Date: _____	Time: _____
Relinquished By:	Date: _____	Received By:	Date: _____	Time: _____

Date Faxed: \_\_\_\_\_

Invoice Number: \_\_\_\_\_

Is sample known to be hazardous? (circle one)

Yes or No

# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST



Customer Name: Midland Park High School  
 Address: 250 Prospect Street  
 Midland Park NJ 07432  
 County/Municipality: Scott Collins  
 Phone: Scollins@MPSNJ.org  
 Work: (973) 989-0156

report to: Agra Environmental Services  
 90½ West Blackwell Street  
 Dover, NJ 07801  
 Phone: (973) 989-0010  
 Fax: (973) 989-0156

Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake Page 1 of 1

Project:	Lab ID:	Collection		PWSID# NJ			ANALYSIS REQUESTED	Field Analysis
		Date	Time	Grab	Comp	Matrix		
	0124	6/3/17	8:04	X		DW	1st Draw PB < 2 µg/L	6/10/17 BM
	0129	6/3/17	8:24	X		DW	1st Draw PB < 2 µg/L	6/10/17 BM
	0135	6/3/17	8:43	X		DW	1st Draw PB < 2 µg/L	6/10/17 BM
	0141	6/3/17	8:50	X		DW	1st Draw PB < 2 µg/L	6/10/17 BM
	0147	6/3/17	9:07	X		DW	1st Draw PB < 2 µg/L	6/10/17 BM
	0153	6/3/17	9:24	X		DW	1st Draw PB < 2 µg/L	6/10/17 BM
	0159	6/3/17	9:41	X		DW	1st Draw PB < 2 µg/L	6/10/17 BM
	0165	6/3/17	9:58	X		DW	1st Draw PB < 2 µg/L	6/10/17 BM
	0171	6/3/17	10:15	X		DW	1st Draw PB < 2 µg/L	6/10/17 BM
	0177	6/3/17	10:32	X		DW	1st Draw PB < 2 µg/L	6/10/17 BM
	0183	6/3/17	10:49	X		DW	1st Draw PB < 2 µg/L	6/10/17 BM
	0189	6/3/17	11:06	X		DW	1st Draw PB < 2 µg/L	6/10/17 BM
	0195	6/3/17	11:23	X		DW	1st Draw PB < 2 µg/L	6/10/17 BM

State Forms Needed (circle one): Yes or No  
 NJDEP Laboratory Certification (Dover, NJ) #14013  
 NJDEP Laboratory Certification (Marlboro, NJ) #13033  
 Reporting Requirements (Check Box):  
 Standard  NJ Reduced  Other (Specify)

Sample Custody Exchanges (Please use full legal signature)		Scanned	
Relinquished By:	Received By:	Date:	Time:
<i>[Signature]</i>	<i>[Signature]</i>	6/21/17	10:55
Relinquished By:	Received By:	Date:	Time:
Relinquished By:	Received By:	Date:	Time:
Relinquished By:	Received By:	Date:	Time:
Relinquished By:	Received By:	Date:	Time:

Date Faxed: \_\_\_\_\_  
 Invoice Number: \_\_\_\_\_  
 is sample known to be hazardous? (circle one)  
 Yes or No



Attachment C – Drinking Water Outlet Inventory  
 (Complete for each school)

Name of School: Midland Park High School Address: 250Prospect Street, Midland Park, NJ 074432

Grade Levels: \_\_\_\_\_ Year School Constructed: \_\_\_\_\_ Renovated/Additions: \_\_\_\_\_

Individual school project officer Name/Signature: \_\_\_\_\_ Date Completed: \_\_\_\_\_

# <sup>1</sup>	Type	Location	Code	Operational? <sup>2</sup> (Y/N)	Signs of Corrosion <sup>3</sup> (Y/N)	Filter (Y/N)	Brass Fittings, Faucets or valves? <sup>4</sup> (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Field Blank												
02	POE	WC- Hall -1	MPHS-POE-01 <i>11/24/15 KJA</i>										
03	POE	WC - Hall -2	MPHS-BOE-02 <i>11/2-0-2 A</i>										
04	FP	Sink 1	MPHS-FP-03										
05	FP	Sink 2	MPHS-FP-04										
06	FP	Sink 3	MPHS-FP-05										
07	FP	Sink 4 Hand Wash	MPHS-FP-06										
08	NS	1fl Nurse's Office	MPHS-1F-NS-7										
09	TL	ROOM 60	MPHS-TL-8										
10	WC	SCIENCE WING Custodial Closet	MPHS-WC-9										

<sup>1</sup> Number outlets starting at the closest outlet to the Point of Entry (POE).

<sup>2</sup> Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

<sup>3</sup> Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

<sup>4</sup> Document on Attachment D- Filter Inventory.

(Midland Park School District) Sampling Plan  
5/17/17  
Version 0

11	WC	SCIENCE WING by-Gustafstad Closet	MPHS-WC -10											
12	WC	Girls Locker	MPHS-WC-11											
13	WC	GIRLS LOCKER	MPHS-WC-12											
14	DW	WEIGHT RM 17	MPHS-DW-13 UJC. 9/13/16											
15	IM	TRAINING ROOM	MPHS-IM-14											
16	WC	BY MEDIA CTR	MPHS-WC-15											
17	WC	By Media CTR	MPHS-WC-16											
18	WC	MS-WING	MPHS-WC-17											
19	WC	MS - WING	MPHS-WC-18 WJ											
19	TL	ROOM 33	MPHS-TL-19											
20	WC	BAND ROOM 13	MPHS-WC-20 WJC											
21	WC	BAND ROOM 13	MPHS-DW-21											
22	DW	BOARD OFFICE	MPHS-DW-22 WC											
23	WC	BOYS LOCKER	MPHS-WC-23							Out of sync				
24	WC	BOYS LOCKER	MPHS-WC-24							out of sync				